

2007 Annual Drinking Water Quality Report (Consumer Confidence Report)

Holmwood Utilities
P.O. Box 387, Lufkin, Texas 75902
District Office: 936-632-7795

Special Notice for the ELDERLY, INFANTS, CANCER PATIENTS, people with HIV/AIDS or other immune problems:

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. The EPA/Centers for Disease Control and Prevention (CDC) guidelines on appropriate means to lessen the risk of infections by *Cryptosporidium* and other microbial contaminants are available from **the Safe Drinking Water Hotline (800-426-4791)**.

Public Participation Opportunities

Date: July 10, 2008

Time: 4:00 PM – 6:00 PM

Location: 210 Lufkin Avenue (ANRA Central Offices)

Phone No: (936) 632-7795

To learn more about future public meetings concerning your drinking water, please contact us. ANRA also welcomes public comments in writing mailed to : Angelina County FWSD #1, P.O. Box 821 Lufkin Texas, 75902.

Our Drinking Water Meets or Exceeds All Federal (EPA) Drinking Water Requirements

This report is a summary of the quality of the water we provide our customers. The analysis was made by using the data from the most recent U.S. Environmental Protection Agency (EPA) required tests and is presented in the attached pages. We hope this information helps you become more knowledgeable about what's in your drinking water.

WATER SOURCES: The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water before treatment include: microbes, inorganic contaminants, pesticides, herbicides, radioactive contaminants, and organic chemical contaminants.

En Español

Este informe incluye información importante sobre el agua potable. Si tiene preguntas o comentarios sobre éste informe en español, favor de llamar al tel. 1-800-282-5634 para hablar con una persona bilingüe en español.

Where do we get our drinking water?

Our drinking water is obtained from GROUND water sources. It comes from the Jasper aquifer. A Source Water Susceptibility Assessment for your drinking water sources(s) is currently being updated by the Texas Commission on Environmental Quality and will be provided to us this year. The report will describe the susceptibility and types of constituents that may come into contact with your drinking water source based on human activities and natural conditions. The information contained in the assessment will allow us to focus our source water protection strategies. For more information on source water assessments and protection efforts at our system, please contact us.

All Drinking Water May Contain Contaminants

When drinking water meets federal standards there may not be any health based benefits to purchasing bottled water or point of use devices. Drinking water, **including bottled water**, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling **the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791)**.

Secondary Constituents

Many constituents (such as calcium, sodium, or iron) which are often found in drinking water, can cause taste, color, and odor problems. The taste and odor constituents are called secondary constituents and are regulated by the State of Texas, not the EPA. These constituents are not causes for health concern. Therefore, secondaries are not required to be reported in this document but they may greatly affect the appearance and taste of your water.

About The Following Pages

DEFINITIONS

Maximum Contaminant Level (MCL)

The highest permissible level of a contaminant in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG)

The level of a contaminant in drinking water below which there is not known or expected health risk. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL)

The highest level of disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG)

The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

Treatment Technique (TT)

A required process intended to reduce the level of a contaminant in drinking water.

Action Level (AL)

The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

ABBREVIATIONS

NTU - Nephelometric Turbidity Units

MFL - million fibers per liter (a measure of asbestos)

pCi/L - picocuries per liter (a measure of radioactivity)

ppm - parts per million, or milligrams per liter (mg/L)

ppb - parts per billion, or micrograms per liter ($\mu\text{g/L}$)

ppt - parts per trillion, or nanograms per liter

ppq - parts per quadrillion, or picograms per liter

Inorganic Contaminants

Year (Range)	Contaminant	Average Level	Min. Level	Max. Level	MCL	MCLG	Unit of Measure	Source of Contaminant
2006	Barium	0.066	0.066	0.066	2	2	ppm	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits.
2004	Gross beta emitters	4.8	4.8	4.8	50	0	pCi/L	Decay of natural and manmade deposits.

Organic Contaminants TESTING WAIVED, NOT REPORTED, OR NONE DETECTED

Maximum Residual Disinfectant Level

Year	Contaminant	Average Level	Min. Level	Max. Level	MCL	MCLG	Unit of Measure	Source of Disinfectant
2007	Chlorine Residual, Free	1.62	0.28	6.1	4	4	ppm	Disinfectant used to control microbes.

Disinfection Byproducts NOT REPORTED OR NONE DETECTED

Unregulated Initial Distribution System Evaluation for Disinfection Byproducts WAIVED OR NOT YET SAMPLED

Unregulated Contaminants NOT REPORTED OR NONE DETECTED

Lead and Copper

Year	Contaminant	90 th Percentile	Number of Sites Exceeding Action Levels	Action Level	Unit of Measure	Source of Disinfectant
2000	Lead	1.3	1	15	ppb	Corrosion of household plumbing systems; erosion of natural deposits.
2000	Copper	0.245	1	1.3	ppm	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.

Recommended Additional Health Information for Lead

All water systems are required by EPA to report the language below starting with the 2009 CCR to be delivered to you by July of 2010. We are providing this information now as a courtesy.

“If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. This water supply is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.”

Turbidity NOT REQUIRED

Total Coliform

Total coliform bacteria are used as indicators of microbial contamination of drinking water because testing for them is easy. While not disease-causing organisms themselves, they are often found in association with other microbes that are capable of causing disease. Coliform bacteria are more hardy than many disease-causing organisms; therefore, their absence from water is a good indication that the water is micro biologically safe for human consumption.					
Year	Contaminant	Highest Monthly Number of Positive Samples	MCL	Unit of Measure	Source of Contaminant
2007	Total Coliform Bacteria	1	*	Presence	Naturally present in the environment.
* Two or more coliform found samples in any single month.					

Fecal Coliform REPORTED MONTHLY TESTS FOUND NO FECAL COLIFORM BACTERIA.

Secondary and Other Constituents Not Regulated

(No associated adverse health effects)

Year or Range	Constituent	Average Level	Min. Level	Max. Level	Secondary Limit	Unit of Measure	Source of Constituent
2007	Bicarbonate	56	56	56	NA	ppm	Corrosion of carbonate rocks such as limestone.
2006	Calcium	1.8	1.8	1.8	NA	ppm	Abundant naturally occurring element.
2007	Chloride	12	12	12	300	ppm	Abundant naturally occurring element; used in water purification; byproduct of oil field activity.
2006	Copper	0.007	0.007	0.007	1	ppm	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.
2006	Iron	1.315	1.31	1.32	.3	ppm	Erosion of natural deposits; iron or steel water delivery equipment or facilities.
2006	Manganese	0.0166	0.0166	0.0166	.05	ppm	Abundant naturally occurring element.
2006	Nickel	0.005	0.005	0.005	NA	ppm	Erosion of natural deposits.
2007	pH	6.6	6.6	6.6	>7.0	units	Measure of corrosivity of water.
2006	Sodium	7	7	7	NA	ppm	Erosion of natural deposits; byproduct of oil field activity.
2007	Sulfate	8	8	8	300	ppm	Naturally occurring; common industrial byproduct; byproduct of oil field activity.
2007	Total Alkalinity as CaCO ₃	46	46	46	NA	ppm	Naturally occurring soluble mineral salts.
2007	Total Dissolved Solids	120	120	120	1000	ppm	Total dissolved mineral constituents in water.
2006	Total Hardness as CaCO ₃	5	5	5	NA	ppm	Naturally occurring calcium.
2006	Zinc	0.182	0.182	0.182	5	ppb	Moderately abundant naturally occurring element; used in the metal industry.



ANRA
P.O. Box 387
Lufkin, Texas 75902

Angelina & Neches River Authority