

Mandatory Language for a Maximum Contaminant Level Violation - TTHM

The Texas Commission on Environmental Quality (TCEQ) has notified the **PRAIRIE GROVE UTILITIES (PWS TX0030027)** public water system that the drinking water being supplied to customers had exceeded the Maximum Contaminant Level (MCL) for total trihalomethanes. The U.S. Environmental Protection Agency (U.S. EPA) has established the MCL for total trihalomethanes to be 0.080 milligrams per liter (mg/L) based on a locational running annual average (LRAA) and has determined that it is a health concern at levels above the MCL. Analysis of drinking water in your community for total trihalomethanes indicates a compliance value in:

Monitoring period	Contaminant Level	Sample point
Quarter 4 2025	0.105 mg/L	DBP2-01: 4661 BUTTER MILK ROAD, DIBOLL, TX
Quarter 4 2025	0.099 mg/L	DBP2-02: 3436 FM 1818, DIBOLL, TX

Trihalomethanes are a group of volatile organic compounds that are formed when chlorine, added to the water during the treatment process for disinfection, reacts with naturally-occurring organic matter in the water.

Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidney, or central nervous systems, and may have an increased risk of getting cancer.

You do not need to use an alternative water supply. However, if you have health concerns, you may want to talk to your doctor to get more information about how this may affect you.

We are taking the following actions to address this issue: The Angelina and Neches River Authority closed on grant funds on November 19, 2024 to construct a water supply line from the City of Diboll, construct a new water treatment plant and replace approximately 80 percent of the distribution system. ANRA has issued the notice to proceed with environmental review and detailed design of the project. It is anticipated that the new water supply and water treatment plant could begin in the summer of 2027.

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact:

Water system official name: Mr. Kelley Holcomb.

Title: General Manager

Phone: (936) 632-7795

Posted / Delivered Date on: March 9, 2026